

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-13-08-19-01

Product: Laminate floor covering with the structures BS, BF, WG, RF, EX, OA, WO, PS, WF, SP, AS, SU, GL, LP, EW, RS, DB, NL, VH, VO, HC, RC

Producer: Kronoflooring GmbH
Mühlbacher Str. 1
01561 Lampertswalde / Dresden

Order: Determination of the slippery resistance according to EN 13893 / classification according to EN 14041

Test reports: 265188
276279
279047
270181
271193
271355
272008
272495


Result: The tested laminate floor covering structures are fulfilling with the values of $\mu = 0.41 - 0.70$ the requirements of the class DS ($\mu \geq 0.30$) according to EN 14041 (CE-labelling).

Dresden, 19 August 2013



Head of laboratory





Engineer in charge